

KNT/KW/16/7395/7421

P.T.O

Explain with neat sketches various regimes of fluidization in a fluidized bed boiler.

b) Write short note on (a) coal- handling (b) Ash handling.

## OR

7

7

6

7

4

13

- 6. a) Explain working principle and applications of cogeneration systems.
  - b) Explain with neat sketches, Topping cycle and bottoming cycle used in cogeneration systems.
- 7. a) Dry saturated steam at a pressure of 11 bar enters a convergent divergent nozzle and leaves at a pressure of 2 bar. If the flow is adiabatic and frictionless, determine.
  - i) The exit velocity of steam.
  - ii) Ratio of cross-section at exit and that at throat.

Assume the index of adiabatic expansion to be 1.135.

- Steam at a pressure of 15 bar and dryness fraction 0.97 is discharged through a convergent divergent nozzle to a back pressure of 0-2 bar. The mars flow rate is 9 kg/ kwh. If the power developed is 220 kw, determine.
  - i) Throat pressure.

a)

ii) Number of nozzles required if each nozzle has a throat of rectangular cross-section of 4 mm x 8 mm.

OR

- iii) If 12% of the overall isentropic enthalpy drop reheats by friction the steam in divergent portion find the cross section of exit rectangle.
- **8.** a) In an installation 5.2 kg/s of steam at 30 bar and 350° C is supplied to group of six nozzles in a wheel diameter maintained at 4 bar. Determine.

i) The dimensions of nozzles of rectangular cross sectional area with aspect ratio 3:1

- The expansion may be considered metastable and friction is neglected.
- ii) Degree of under cooling and supersaturation.
- iii) Loss in available heat drop due to irreversibility
- iv) Increase in entropy.
- b) Write short note on compounding of steam turbines.

The following data refers to a compound impulse turbine having two rows of moving blades and one row of fixed blade in between them velocity of steam leaving the Nozzle = 600 m/s.

VOZZIE = 000 m/s.

9.

Nozzle angle =  $20^{\circ}$ ,

Blade speed = 125 m/s.

- First moving blade outlet angle  $= 20^{\circ}$
- First fixed blade outlet angle  $= 25^{\circ}$
- Second moving blade outlet angle  $= 30^{\circ}$ .
- Friction loss in each stage = 10% of relative velocity. Find
- a) Diagram efficiency.
- b) Power developed if the steam flow rate is 300 kg/s

OR

KNT/KW/16/7395/7421

In a reaction turbine, the blade tips are inclined at 35 ° and 20° in the direction of motion. The guide blades are of the same shape as the moving blades but reversed in direction. At a certain place in the turbine, the drum diameter is 1 m and blades are 10 cm high At this place, the steam has a pressure of 1.75 bar and 0.935 dry If the speed of the turbine is 2500 r.p.m and the steam passes through the blades without shock, find the mass of steam flow and power developed in the ring of the moving blades.

5

9

9

5

- b) Define the term 'degree of reaction' as applied to a steam turbine. show that for parson's reaction turbine the degree of reaction is 50%.
- 11. a) In a surface condenser a section of the tubes near to the air pump suction is screened off so that the air is cooled to a temperature below that of the condensate, separate extraction pumps being provided to deal with air and condensate respectively. 5448 kg of steam are condensed per hour and the air leakage is 4.54 kg/h. The temperature of exhaust steam is 21.1° C. Assuming a constant vacuum throught the condenser, find:
  - i) The mass of steam condensed per hour in the air cooler.
  - ii) The volume of air in  $m^3/h$  to be dealt with by the air pump.
  - b) State the sources of air in condenser and explain the construction and working of a surface 5 condenser.

## OR

 a) During a trial on a steam condenser, the following observations were recorded. Condenser vacuum = 680 mm of Hg Barometer reading = 764 mm of Hg Mean condensate temperature = 36.2° C Hot well temperature = 30° C

Condensate formed per hour = 1780 kg

- Cooling water inlet temperature =  $20^{\circ}$  C
- Cooling water outlet temperature =  $32^{\circ}$  C
- Quantity of cooling water = 1250 kg/min
- Determine:

10.

- i) Condenser vacuum corrected to standard barometer.
- ii) Vacuum efficiency.
- iii) Under cooling of condensate.
- iv) Condenser efficiency.
- b) Write short note.
  - i) Evaporative condenser.
  - ii) Natural draught cooling tower.

\*\*\*\*\*

## KNT/KW/16/7395/7421

